


Domestic Installation

Dt-13/12/19

Q. The plan of a single room of size 5m x 4m is given below. The room is required to be provided with one lamp, one fan, one fluorescent tube ISA socket individual switch, draw the installation plan & its wiring diagram. Calculate the total length of wire & other material & prepare a list of material required for wiring the room in concealed conduit wiring system.



* Assumes -

- Total height floor to ceiling = 3.5m
- Height of horizontal run from floor = 3.0m
- Height of s/w board from floor = 1.5m
- Height of tube point from ceiling = 0.5m

* Calculate the length of conduit pipe :-

- From s/w board (20mm dia) to horizontal run = 1.5m
- Floor to Energy meters = 2 + 0.5 = 2.5m

→ From HR to lamp point =
 $0.5 + 0.5 + 4 = 5\text{m}$

→ From bath to tube point = $2.5 + 0.5 = 3$

→ Taking 10% wastage. $12 \times \frac{10}{100} = 1.2\text{m}$ Total = $12\text{m} + 1.2\text{m}$

→ Total length of conduit pipe = $12 + 1.2 = 13.2$

* Calculation the length of phase wire:-

→ From point of entry of ckt into room upto
Sw board (SB) = $2.0 + 1.5 = 3.5\text{m}$

→ From SB upto bath = $1.5 + 0.5 + 0.5 + 2 = 4.5\text{m}$

→ From SB to lamp = $4.5 + 1.5 + 0.5 + 0.5 = 7\text{m}$

→ From SB to tube = $4.5 + 2.5 + 0.5 = 7.5\text{m}$

→ Calculation of the length of Neutral wire:- 22.5m

→ From point of entry of ckt into room upto
Sw board = 3.5m

→ From bath to lamp = 2.5m

→ From bath to tube = 3m

→ Total length of conductors = $3.5 + 4.5 + 2.5 + 3$
 $= 13.5\text{m}$

→ Total length of conductors (Phase / neutral)
 $= 13.5 + 22.5$
 $= 36\text{m}$

* Taking 15% wastage =


$$= 36 \times \frac{15}{100}$$

$$= 5.4m$$

Total = $36 + 5.4 = 41.4m$

* Earth wire calculation :-

* From energy meter to s/w board = $\frac{Dt-14/12/19}{}$
 $1.5 + 1.5 + 0.5 = 3.5m$




Sl. No.	Material list :- Name & specification	Quantity
01.	Conduit pipe (20mm dia)	13.2m
02.	Phase neutral wire (1.2mm ²)	41.4m
03.	Earth wire (1.6mm ²)	3.5m
04.	Switch (5Amp)	4 no.
05.	Socket (5A)	1 no.
06.	Regulation (220v)	1 no.
07.	S/w board (20cm x 20cm)	1 no.
08.	lamp holders	1 no.
09.	Thimble	1 no.
10.	L-band pipe	3 no.
11.		

Q. A room and veranda the plan of which is given below is require to be provided with electrical wiring. Mark the location of energy meter, main S/w & S/w board and electrical points suitably. and draw the installation plan. so supply path to each point & wiring diagram. calculate the total length of wire require for wiring diagram for the room & veranda in battery wiring system.

Prepare a list of material with complete specification of each items.

Dt-07/01/2020

1) Installation plans



2) Assume :- Energy meter from floor = 2M

i) The height of ceiling = 3.5M

ii) Height of H.R. from floor = 3M

iii) Height of S/w board from floor = 1.5M

iv) location of EM & Main SB = 0.5M

v) (Inside veranda on room wall)

3) Calculation of load :-

$$\text{Lamp} \rightarrow 2 = 120 \text{ watt} = 60w \times 2$$

$$\text{Fan} \rightarrow 2 = 120 \text{ watt} = 60w \times 2$$

$$\text{Socket} \rightarrow 2 = 200 \text{ watt} = 100w \times 2$$

$$\text{F.T. (Light)} - 1 = \frac{40 \text{ watt}}{40w \times 1}$$

$$\text{Total} \rightarrow 480 \text{ watt}$$

$$\text{voltage} = 230 \text{ V}$$

$$\Rightarrow \text{current} = \frac{\text{Power}}{\text{voltage}} = \frac{480}{230} = 2.08 \text{ Amp}$$

4) selection & rating of main sw :-

The 5A, 250V DPIC main sw is selected.
(Double pole iron clad)

5) Calculation for length of pipe (batten) :-

i) Main SB to HR = 1M (13x13mm, 2 wire)

ii) From BM to SB = 1.5 + 1.5 = 3M
4m (13x13mm, 2 wire)

iii) From SB-1 to H.R = 1.5M (25x13mm, 4 wire)

iv) From SB-2 to HR = 1.5m (31x13mm, 5 wire)

v) From HR to fan-1 = 0.5m + 1.5m = 2m (13x13mm, 2 wire)

vi) From HR to fan-2 = 0.5 + 2 = 2.5m (25x13mm, 4 wire)

vii) From fan 2 to lamp = 2.5M (13x13mm, 2 wire)

viii) From Fan 2 to F.T. = 2.5M (13x13mm, 2 wire)

A) 13x13mm, 2 wire = 4 + 2 + 2.5 + 2.5 = 11m

B) 25x13mm, 4 wire = 1.5 + 2.5 = 4m

C) 31x13mm, 5 wire = 1.5m

A) Wastage of 13x13mm, 2 wire = 11m \Rightarrow total = 11 + 1.1 = 12.1m
10% wastage = $11 \times \frac{10}{100} = 1.1 \text{ M}$

B) Wastage of 25x13mm, 4 wire = 4m \Rightarrow total = 4 + 0.4 = 4.4m
10% wastage = $4 \times \frac{10}{100} = 0.4 \text{ m}$

C) Wastage of 31x13mm, 5 wire = 1.5m \Rightarrow total = 1.5 + 0.15 = 1.65m
10% wastage = $1.5 \times \frac{10}{100} = 0.15 \text{ M}$

Length of conductors:-

- 01. 13 x 13 mm, 2 wire = 11 x 2 = 22 M
- 02. 25 x 13 mm, 4 wire = 4 x 4 = 16 M
- 03. 31 x 13 mm, 5 wire = 1.5 x 5 = 7.5 M

15% wastage =
 $\Rightarrow 15 \times \frac{45.5}{100} = 6.825$
 $\Rightarrow \text{total} = 6.825 + 45.5 = 52.325 \text{ m}$

Total length = 22 M + 16 M + 7.5 M = 45.5 M

Calculation for length of earth wire:-

\rightarrow SB to SB1 to SB2 = 1 + 1.5 + 1.5 + 0.25 = 4.25 m

10% wastage = $4.25 \times \frac{10}{100} = 0.425$

\rightarrow total = 4.25 + 0.425 = 4.675 m

* Material list:-

- i) DPIC main 5/10 (5 amp, 230V)
- ii) Batten (13 x 13 mm) = 11 m
- iii) " (25 x 13 mm) = 4 m
- iv) " (31 x 13 mm) = 1.5 m
- v) Total phase & neutral wire = 45.5
- vi) Switch (5 Amp) = 7 no.
- vii) Fan = 2 no.
- viii) Socket = 2 no.
- ix) Lamp = 2 no.
- x) F. Tube = 1 no.
- xi) Fan Regulator = 2 no.
- xii) S

A newly constructed verandah room & an attached bath room are required to be provided with electrical wiring suitable. The bath room must be provided with one 15 amp. socket apart from a lamp. The lamp outside the verandah must be controlled from

inside the room also. Decide the room of electrical points suitable to provided max possible convenience to the consumers.

* Inst

* Asses

i) Heig

ii) Heig

iii) Heig

iv) Heig

* Calc

i) F

ii) L


iii) T

iv) S

v) 15 A

* Sele

* Installation plane :-



* Assumption :-

- ∴ Height of ceiling from floor = 3.5m
- ∴ Height of H.R from floor = 3m
- ∴ Height of S.B from floor = 1.5m
- ∴ Height of main sw from floor = 2m

* Calculation of load :-

- ∴ Fan → 2 = 2 × 60w = 120w.
- ∴ Lamp → 4 = 4 × 60w = 240w.
- ∴ Tube → 1 = 1 × 40w = 40w.
- ∴ Socket → 3 × 100w = 300w.
- ∴ 15A socket = 1000w.

$$\text{Total} = 1700 \text{ watt}$$

$$I = \frac{P}{V} = \frac{1700}{230} = 7.39 \text{ Amp.}$$

* Selection & rating of main sw :-

15 Amp, 250V, DPIC main switch.

* Calculation of conduit pipe :-

i) Energy meter to SW board = $1.5 + 1.5 + 0.5 = 3.5m$
(Verandah) : (13 x 13mm)

ii) SB₁ to lamp = $1.5m$
(25mm x 13mm 4 wire system)

iii) H.R. to Fan (lamp to fan) = $0.5 + 1.5 = 2m$
(25 x 13mm 3 wire)

iv) Fan-1 to Lamp-2 = $1.5 + 0.5 = 2m$
(13 x 13mm 2 wire)

Room :-

v) SB-2 to Lamp-3 = $1.5m$ (25 x 13mm 4 wire)

vi) H.R. to Fan-2 = $0.5 + 2 = 2.5m$
(25 x 13mm 3 wire) $\Rightarrow 2.5 \times 2 = 5m$

vii) Fan-2 to SB-3 = $2 + 0.5 + 1.5 = 4m$
(13 x 13mm 2 wire)

viii) SB-3 to tube = $1.5m$ (25 x 13mm 3 wire system)

ix) Tube to SB-4 = $2m$ (13 x 13mm 2 wire)

* 13 x 13mm conduit :-

$$3.5 + 2 + 4 + 2 = 11.5m$$

\rightarrow 10% wastage ; $\frac{11.5 \times 10}{100} = 1.15m$

\rightarrow Total = $1.15 + 11.5 = 12.65m$

* 25 x 13mm conduit :-

$$1.5 + 2 + 1.5 + 5 + 1.5 = 11.5m$$

\rightarrow wastage 10% = $1.15m$

\Rightarrow total = $11.5 + 1.15 = 12.65m$

* Conduit for power ckt :-

* Energy meter to power ckt ;

$$= (0.5 + 1.5 + 0.25 + 1.5 + 0.5 + 4 + 0.5 + 1.5 + 0.25 + 1) = 11.5m$$

$$= 11.5m$$

\rightarrow wastage 10% = $1.15m$

\rightarrow Total

\rightarrow Calcula

* For 1

\rightarrow Ener

\rightarrow SB


\rightarrow SB

It is proposed to install a power cable of 3 ϕ SHP IM for an agriculture tubel in the room of size 3x3x3m (LxWxH). The motor is 1M away from the nearest wall. Prepare the estimate in the following orders:-

- Draw the installation plant
- Single line diagram
- Wiring diagram
- Calculate length of wire
- Conduct & earth wire & prepared the material list.

* Assumptions:-

- The motor will be installed 0.5m above floor level on a suitable foundation.
- Slw.B. to floor = 1.5m
- Energy meter to floor = 2m



* Load Calculation:-

$$\begin{aligned} \text{SHP} &= 5 \times 746 \\ &= 3730 \text{ watt} \\ \cos \phi &= 0.8, \quad V = 400V \end{aligned}$$

$$P = \sqrt{3} V I \cos \phi$$

$$\Rightarrow I = \frac{3730}{\sqrt{3} \times 0.8 \times 400} = 6.72 \text{ amp}$$

→ Taking 150% over loading, so the load I drawn by the motor =

$$6.72 \times \frac{150}{100} = 10.08 \text{ Amp} \quad \Rightarrow 6.72 + 3.36 = 10.08 \text{ amp}$$

* Selection & rating of main slw :-

1600 Amp, 400V, TPIC main slw to be selected.

* Conduit pipe calculation:-

(Trench = 0.25m)

→ Main board to top of the motor foundation =

$$1.5 + 0.25 + 1 + 0.25 + 0.5 = 3.5 \text{ m}$$

* Wastage 10% = 0.35

$$\Rightarrow \text{Total} = 3.5 + 0.35 = 3.85 \text{ m (25 x 25 mm dia pipe)}$$

→ Conduit for earth wire (15mm dia)

$$3.5 \times 2 = 7 \text{ m}$$

→ Wastage 10% = 0.7m (Rigid conductors)

$$\Rightarrow \text{Total} = 7 + 0.7 = 7.7 \text{ m}$$

- * Calculation for
- Energy meter to
 - Main switch board
 - Starter to top
 - Foundation to mo

* Wastage 10% =


$$\Rightarrow \text{Total} = 2.5$$

- * Calculation for
- The conduit has
 - ∴ length wire =

* Wastage 15% =

$$\Rightarrow \text{Total} = 18$$


- length of earth
- * Wastage 15%
- 1M extra for



* Material list:-

- Main slw
- Conduit pipe
- Earth wire
- Phase wire
- Motor
- Starter
- Saddle

IM
3x3m
est
80%
repaired



dy
amp
(m)

(pipe)

* Calculation for the length of flexible conduit :-

- Energy meter to main SW = $0.5 + 1 = 1.5m$
- Main switch board to starter = $0.5m$
- Starter to top of the pipe = $0.25m$
- Foundation to motor terminal = $0.25m$

* wastage 10% = $0.25m$ 2.5m

→ Total = $2.5 + 0.25 = 2.75m$

* Calculation for length of wire :-

- The conduit has 3 wire i.e. 3 wire for 3φ.
- ∴ length wire = length of conduit (Rigid + flexible) × 3

= $3.5 \times 3 = 10.5$

= $2.5 \times 3 = \frac{7.5}{18.0m}$


* wastage 15% = $2.7m$

→ Total = $18 + 2.7 = 20.7m$

→ length of earth wire = $7m$

* wastage 15% = 1.05 → total = $7 + 1.05 = 8.05m$

→ 1m extra for around the main board.



* Material list :-

- 1) Main SW
- 2) Conduit pipe
- 3) Earth wire
- 4) Phase wire
- 5) Motor
- 6) Starter
- 7) Saddle
- 8) Gutter
- 9) Danger plate
- 10) Flexible wire


Q. In a workshop of size $25\text{m} \times 10\text{m}$, the plan of which given below; at 10BHP, 400 volt, 3ϕ IM is to be installed for a wood cutting m/c. The service conn'g are received in one corner of the workshop from nearest distribution pole. Prepare the estimate scheme in the following sequence.

(i) Draw the installation plan & showing the location of main control equipment, motor & motor control.

(ii) Single line diagram.

(iii) Wiring diagram

(iv) Calculate the length of wire, conduit, earth wire, prepare a complete list of material for installing motor for a workshop.



* Assumptions :-

1) Energy meter from floor = 2m

2) Main SW & starter from floor = 1.5m

3) Foundation height = 0.5m

* Load Calculation :-

$$P_{\text{max}} = 7.355 \times 10 = 73.55 \text{ watt} = 7.355 \text{ KW}$$

$$V = 400\text{v}, \quad \cos \phi = 0.8$$

$$P = \sqrt{3} V I \cos \phi$$

$$\Rightarrow I = \frac{73.55}{\sqrt{3} \times 400 \times 0.8} = 13.27 \text{ Amp}$$

an ob
N is to be
service
the
Preparae
egence.
ation of
ol.

→ Taking 150% over loading, so the load I drawn
by the motor = $13.27 \times \frac{150}{100} = 19.905 \text{ A} = 20 \text{ Amp.}$

* Select & rating of main SW:-

32 amp, 660 v. TPIC main SW to be selected.

→ Conduit pipe calculation:-

Main SW board to the top up the motor foundation:

$$1 + 20 + 1.5 + 0.25 + 1 + 0.25 + 0.5 = 24.5$$

→ Taking 10% wastage = $24.5 \times \frac{10}{100} = 2.45$

$$\text{Total} = 24.5 + 2.45 = 26.95$$

→ Conduit earth wire:-

$$26.95 \times 2 = 49 \text{ m}$$

→ 10% wastage = $49 \times \frac{10}{100} = 4.9 \text{ m}$

$$\text{Total} = 49 + 4.9 = 53.9 \text{ m}$$

* Calculation for the length of flexible conductors:-

→ From main SB to starters = 0.5 m

From energy meters = 0.5 m

For starters to conduit mouth = 0.25 m

→ From motor foundation to motor terminal block = 0.25 m

$$\Rightarrow \text{Total flexible} = \underline{1.5 \text{ m}}$$

→ 10% wastage = $1.5 \times \frac{10}{100} = 0.15$

$$\text{Total} = 1.5 + 0.15 = 1.65 \text{ m}$$

* Calculation for length of wires:-


The conduit has 3 wires i.e. 3 wires for 3φ.

$$\therefore \text{length of wire} = (26.95 + 1.5) \times 3 = 78 \text{ m}$$

→ 15% of wastage = $78 \times \frac{15}{100} = 11.7 \text{ m}$

$$\Rightarrow \text{Total} = 78 \text{ m} + 11.7 \text{ m} = 89.7 \text{ m}$$

wire
installing



* Calculation of earth wire :-


→ The conduit of earth wire =

$$24.5 \times 2 = 49m$$

→ 15% wastage = $49 \times \frac{15}{100} = 7.35m$

$$\text{Total} = 49 + 7.35 = 56.35$$

* Single line diagram :-



* Material list :-

- 1) Conduit pipe
- 2) Flexible pipe
- 3) Earth wire
- 4) Phase wire
- 5) Main SW
- 6) Starter
- 7) Motor
- 8) Energy meter
- 9) clamp
- 10) Saddle

→ A small workshop of size $10m \times 6m \times 4m$ high is under construction. It is required to be provided with the following power connections for motors. The electrical connections to motors are to be taken along wall i.e. the floor is not to be provided with any wiring trench.

1. One 5HP 3 ϕ motor for lathe.
2. One 3HP 3 ϕ motor for a small lathe.
3. One 2HP 3 ϕ IM for an automatic cool

manub
4. One c
5. One g
Prepara
(a) Draw
main s
board
motor
(b) Draw
energy
(c) Draw
earth
& 3 ϕ
(d) Make
the le
prepara
of ite
provid

→ Assu
1) Height
for
2) Height
3) Cost o
the e
4) Main
one me
of m
5) Height
drilling
6) Height
as the

manufacturing m/c.

4. One drilling m/c driven by a 1 ϕ 1HP motor.

5. One grinding m/c driven by a 0.5HP 1 ϕ motor.

Prepare the complete estimate in the following sequence:

(a) Draw installation plan showing location of m/c, main s/w & power distribution board motor control boards etc. show path of power wiring to each motor.

(b) Draw single line diagram starting from the energy meter.

(c) Draw wiring diagram of main board including earth wire connections showing connection of 1 ϕ & 3 ϕ energy meters, main s/w & distribution board.

(d) Make selection of important material & calculate the length of wire, conduit, earth wire etc. & prepare a material table with full specifications of items. Also estimate approximate cost for providing power wiring in the workshop.

Assumptions :-

1. Height of main s/w, motor s/w & control s/w from floor = 1.5m


2. Height of horizontal run from floor level = 2.5m

3. Cost of motor & starter is not to be included in the estimate

4. Main distribution board or main control board is one metre from nearest corner of wall (centre of main board).

5. Height of motor for all 3 ϕ & 1 ϕ motor except drilling m/c motor is 0.5mt. above floor.

6. Height of drilling m/c is 1.5mt. above floor as the motor is mounted on the drilling stand.



* Calculation of load :-

$$\rightarrow I_L \text{ for } 5\text{HP motor} = \frac{5 \times 735.5}{400 \times \sqrt{3} \times 0.8 \times 0.75} = 8.86 \text{ Amp}$$

$$\rightarrow I_L \text{ for } 3\text{HP motor} = \frac{3 \times 735.5}{400 \times \sqrt{3} \times 0.8 \times 0.75} = 5.3 \text{ Amp}$$

$$\rightarrow I_L \text{ for } 2\text{HP motor} = \frac{2 \times 735.5}{400 \times \sqrt{3} \times 0.8 \times 0.75} = 3.53 \text{ Amp}$$

$$\rightarrow \text{Total } I_L = 8.86 + 5.3 + 3.53 = 17.69 \text{ Amp}$$

→ Assuming 50% overload on all motor :-

$$\frac{50 \times 17.69}{100} = 8.84 \text{ Amp}$$

$$\rightarrow \text{Total } I_L = 17.69 + 8.84 = 26.53 \text{ Amp}$$

4. One drilling machine driven by a single phase one HP motor.
 5. One grinding machine driven by a 0.5 HP single phase motor.
- Prepare the complete estimate in the following sequence :
- (a) Draw installation plan showing location of machines, main switch and power distribution board, motor control boards etc. Show path of power wiring to each motor.
 - (b) Draw single line diagram starting from the energy meter.
 - (c) Draw wiring diagram of main board including earth wire connections showing connection of single phase and three phase energy meters, main switches and distribution boards.
 - (d) Make selection of important material and calculate the length of wire, conduit, earth wire etc. and prepare a material table with full specifications of each item. Also estimate approximate cost for providing power wiring in the workshop.

Assumptions :

- (a) Height of main switch, motor switch and control switch from floor = 1.5 m.
- (b) Height of horizontal run from floor level = 2.5 m.
- (c) Cost of motor and starter is not to be included in the estimate.
- (d) Main distribution board or main control board is one metre from nearest corner of wall (centre of main board).
- (e) Height of motors for all 3 phase and single phase motors except drilling machine motor is 0.5 mt. above floor.
- (f) Height of drilling machine is 1.5 mt. above floor as the motor is mounted on the drilling stand.

Calculation of load in amperes. Assuming efficiency of 3 phase motor 0.75 and power factor 0.8.

$$\text{Therefore } I_L \text{ for 5 HP motor} = \frac{5 \times 735.5}{400 \times \sqrt{3} \times 0.75 \times 0.8} = 8 \text{ Amps (approximately)}$$

$$I_L \text{ for 3 HP motor} = \frac{3 \times 735.5}{400 \times \sqrt{3} \times 0.75 \times 0.8} = 4.5 \text{ Amps approx.}$$

$$I_L \text{ for 2 HP} = \frac{2 \times 735.5}{\sqrt{3} \times 400 \times 0.75 \times 0.8} = 3.2 \text{ Amps approx.}$$

Total current in amperes for three 3 H.P. motors = 8.0 + 4.5 + 3.2 = 15.7 Amps

Assuming a 50% overload on all motors, the total current drawn = 15.7 + 7.8 (50% overload) = 23.5 amperes

Future extensions may not be possible due to sufficient number of motors already installed in the workshop within the limited space.

Selection and Rating of TPIC Main Switch. The maximum current demand for power loads will be only 23.5 amperes as calculated above. It is therefore suggested that : a TPIC main switch of 45 amperes rating, 500 volts grade should be used as Main Switch.

Selection and Rating of TPIC Motor Switches. The maximum current demand for a highest rating motor (5 HP) is only 8 amperes. Assuming that the motor may have to run on 50% overload for some period of time, the maximum current demand is only 12 amperes. It is therefore suggested that : a TPIC motor switch of 32 amperes rating 500 volts grade should be selected for 5 HP motor and 16 amperes TPIC motor switches for the remaining three phase motors.

Selection and Rating of DP, Single Phase Main Switches for Single Phase Load :

The single phase load of two single phase motors does not exceed 6.2 amps (for one HP motor) + 3.5 amps (for half HP motor) = 9.8 amps say 10 amperes.

Assuming an equal load of single phase on light/fan/sockets. The total single phase load will not exceed 20 amperes if all the load is switched on simultaneously. It is therefore suggested that :

- (a) a DPIC main switch of 30 amperes rating, 250 volts grade should be used as single phase main switch.

18.24

(b) 15 amperes one way switches with 15 amperes socket should be used as control switch for single phase motors.




Fig. 18.17.

Selection and Rating of wire for Main Board, 5 HP motor and 3 HP motor :

For Main Board. The total load for hundred percent utilisation and 50 percent over load for motors is 23.5 amperes. The single core wire to carry this load should be selected as referred on Table No. 18.1.

“Single core PVC insulated aluminium conductor wire of size 7/1.70 dia. or 16 mm² should be used.”

For 5 HP, 3 phase Motor. Refer Table 18.1 for selection of wire for 5 HP 3 phase motor which refers to ‘6 mm² or 1/2.80 mm diameter, single core, aluminium conductor, PVC insulated wire’.

For 3 HP, 3 phase Motor. Again refer Table 18.1 for selection of wire for 3 HP and 2 HP motors which is ‘single core PVC insulated wire of size 4 mm², Aluminium conductor, 660 volts grade.’

Calculations for length of heavy gauge conduit pipe of 25 mm diameter :

From MDB (Power) to 5 HP Motor = 1.0 (DB to horizontal run) + 2.0 (along horizontal run (HR) + 1.0 (HR to motor control board) + 1.5 (motor starter to floor level) + 0.25 (depth of trench) + 2.0 (along trench in floor) + 0.25 (trench bottom to floor level) + 0.5 (floor to motor bottom or floor to motor foundation top) = 8.5 mts

From MDB to 3 HP Motor = 1.0 + 5.0 + 1.0 + 1.5 (upto floor) + 0.25 + 2.0 + 0.25 + 0.5 = 11.5 mts

From MDB to 2 HP Motor = 1.0 + 8.0 + 1.0 + 1.5 + 0.25 + 2.0 + 0.25 + 0.5 = 14.5 mts.

Total length of conduit = 8.5 + 11.5 + 14.5 = 34.5 mts.

Total length of conduit pipe taking 10% wastage = 34.5 + 3.45 = 37.95 mts say 38 mts.

Calculations for length of heavy gauge conduit pipe of 20 mm dia. for single phase motors :

From MDB (lighting) to 0.5 HP Grinding Machine : 1.0 + 2.5 + 1.0 (upto motor switch) + 1.5 + 0.25 + 1.0 + 0.25 + 0.5 = 8.0 mts.

From DB (lighting) to 1 HP Drilling Machine : 1.0 + 4.5 + 1.0 + 1.5 (motor is installed 1.5 mt above floor) + 0.25 + 1.0 + 0.25 + 1.5 = 11.0 mts.

Total length of conduit pipe as calculated above for both motors = 19.0 mts.

Total length of conduit required taking 10% wastage = $19.0 + 1.9 + 20.9$ say 21 mts.

Calculations for length of wire of size 6 mm² or 1/2.80 mm for 5 HP motor :
Total length of conduit pipe for 5 HP motor $\times 3$ wires i.e. $34.5 \text{ mts} \times 3 \text{ wires} = 103.5 \text{ mts}$.
(Because each conduit has three wires in it)
Taking 15% wastage = $103.5 + 15.5$ (wastage) = 119 mts say 120 mts.

Calculations for length of wire of size 4 mm² or 1/2.24 mm for 3 HP and 2 HP Motor :

Total length of conduit pipe for 3 HP motor + 2 HP motor = $11.5 + 14.5 = 26.0 \text{ mts} \times 3 \text{ wires}$
= 78.0 mts.
Taking 15% wastage = $78.0 \text{ mts} + 11.7$ (15% wastage) = 89.7 m say 90 mts.

Calculations for length of wire of size 2.5 mm² or 1/1.80 mm dia. for both single phase motors :

Total length of conduit pipe for both single phase motors as calculated above
= $19 \text{ mts} \times 2 \text{ wires} = 38 \text{ mts} \times 2 \text{ wires} = 76.0 \text{ mts} + 11.4 \text{ mts}$ (15%) Wastage
= 87.4 mts say 88 mts.

Calculations for 8 SWG earth wire of G.I. for 3 phase motors : Each three phase and single phase induction motor will be connected with two earth wires independently which will run along the conduit pipes from distribution board upto motor. Two separate earthing sets will therefore be used.

Total length of earth wire = Total length of conduit pipe (for three phase and single phase motors $\times 2$ wires + 10% wastage
= $34.5 \text{ m} + 19.0 = 53.5 \times 2 \text{ wires} = 107 + 10.7$ (wastage) = 117.7 mts say 118 mts.


Calculations for the length of 15 mm dia. G.I. pipe to enclose earth wires from Motor control boards to motors but for 3 phase motors only

From motor control board to 3 phase motor = $1.5 + 0.25 + 2.0 + 0.25 + 0.5 = 4.5 \times 2 \text{ pipes} = 9.0 \text{ mts}$
Same length of pipe for each three phase motor = $3 \times 9 \text{ mts} = 27 \text{ mts}$
Taking wastage @ 10% = $27 + 2.7 = 29.7 \text{ mts}$ Say 30 Metres

Table 18.6. Material Table

S. No.	Description of Material with Specifications	Quantity	Rate	Amount
1.	TPIC, main switch, 45 amps rating, 500 volts grade with built in HRC fuses	1 No.	450.00/each	450-00
2.	TPIC, motor switch, 32 amps rating, 500 volts grade with fuses	1 No.	270.00/each	270-00
3.	TPIC, motor switches, 16 amps rating, 500 volts grade with fuses	2 Nos.	125.00/each	250-00
4.	Iron Clad Distribution Board ICDB (Power) for 3 motors 45 amps rating 500 volts grade with built-in copper bus bars and fuses	1 No.	225.00/each	225-00
5.	Double Pole Iron Clad DPIC (lighting) main switch of 30 amps rating 250 volts grade as single phase main switch	1 No.	80.00/each	80-00
6.	ICDB (lighting), 6 way, with neutral link, 30 amps rating, 250 v. grade	1 No.	150.00/each	150-00
7.	15 amps one way switch and socket combined for single phase motors	2 sets	40.00/each	80-00
8.	Heavy gauge conduit of size 25 mm dia. black enamel for 3 ϕ motors	38 mts	30.00/mt.	114-00
9.	Heavy gauge conduit of size 20 mm dia. black enamel for 1 ϕ motors	21 mts	20.00/mt.	420-00

Installation plan 5 J





ELECTRICAL DESIGN ESTIMATING AND COSTING

ELECTRICAL INSTA

18.26

10.	(a) Conduit accessories for 25 mm dia. conduit :	12 Nos.	12.00/each	144-00
	Conduit bends	3 Nos.	10.00/each	30-00
	Conduit junction boxes to facilitate pulling of wires in conduits	10 Nos.	6.00/each	60-00
	Conduit sockets to connect two pieces of conduits	30 Nos.	3.00/each	90-00
	Conduit saddles to hold conduit with wall			
	(b) Conduit accessories for 20 mm dia. conduit :	8 Nos.	10.00/each	80-00
	Conduit bends	2 Nos.	8.00/each	16-00
	Conduit junction boxes	4 Nos.	5.00/each	20-00
	Conduit sockets	15 Nos.	3.00/each	45-00
	Conduit saddles			
11.	G.I. pipe of 15 mm diameter for earthwires to motor frames for 3φ motors	30 mts.	30.00/mt.	90-00
	Conduit accessories for 15 mm diameter G.I. pipe :	6 Nos.	12.00/each	72-00
	Conduit bends	3 Nos.	8.00/each	24-00
	Conduit sockets	10 Nos.	3.00/each	30-00
	Conduit saddles			
12.	PVC insulated, single core, aluminium conductor wire of size 7/1.70 mm dia. or 16 mm ² for wiring the Main Board	5 mts.	5.00/mt.	25-00
13.	PVC insulated, single core, aluminium conductor wire of size 6 mm ² or 1/2.80 mm dia. for supply to 5 HP motor	120 mts.	4.00/mt.	480-00
14.	PVC insulated, single core, aluminium conductor wire of size 4 mm ² or 1/2.24 mm dia. for 3 HP & 2 HP motors	90 mts.	2.80/mt.	252-00
15.	6 mm ² or 1/2.80 mm diameter, al. conductor, PVC insulated, single core wire for wiring the main board for single phase	2 mts.	4.00/mt.	8-00
16.	2.5 mm ² or 1/1.80 mm diameter, al. conductor, PVC insulated, single core wire for wiring the single phase motors	88 mts.	2.30/mt.	202-40
17.	Galvanised Iron (G.I.) earth wire, 8 SWG for earthing motors, MB etc.	118 mts.	3.00/mt.	354-00
18.	Iron clad board for mounting main switch, and ICDB 'Power' of size 45 cm × 60 cm	1 No.	300/each	300-00
19.	Iron clad board for mounting single phase main switch, and ICDB 'Lighting' 30 cm × 45 cm	1 No.	180.00/each	180-00
20.	Iron clad board for mounting motor switch, and starter of size 30 cm × 30 cm	3 Nos.	130.00/each	390-00
21.	Rag bolts with nuts for fixing iron clad boards with wall 12 mm diameter 150 mm long four bolts for each board	8 Nos.	5.00/each	40-00
22.	10 mm diameter, 50 mm long bolts with nuts to hold both main switches, distribution boards, 3 motor switches and starters with iron clad boards	40 Nos.	2.00/each	80-00
23.	G.I. thimbies with nuts and bolts for connecting earth wires with main switches, DB's, motor switches starters etc.	40 Nos.	3.50/each	140-00
24.	Flexible conduit of 25 mm diameter @ 1.5 mt. for each motor approximately plus conduit required for main board	5.0 mts.	20.00/mt.	100-00
25.	Flexible conduit of 20 mm dia. for both single phase motors	2.0 mts.	15.00/mts.	30-00
26.	Flexible conduit attachment with lock nuts for 25 mm dia. pipe	18 Nos.	5.00/each	90-00

27.	Flexib
28.	Flexib
29.	Flexi
30.	15 c
31.	Rag
32.	Tea
33.	We
34.	Ca
35.	SH
36.	Es
	w
	th
	s
37.	C
	f
	n
38.	
39.	
40.	
41.	
	Es
	with one
	machine
	marking
	motor s
	3 wire
	estim
	A
	1
	2
	3



Q) A pole for an overhead line 11KV 3 ϕ 50Hz line is reqd to be earth & a stay is to be provided. Make a neat sketch showing how it should be done. Prepare a list of materials required and estimate the cost.

Dt - 11/03

Estimate the quantity of material req^d for 100KV pole mounted distribution substation also draw the sketch.

⇒ Assumption :-

→ H type pole mounted substation is adopted.

⇒ Primary current :-

$$P = \sqrt{3} \cdot V \cdot I$$

$$\Rightarrow I_1 = \frac{P}{\sqrt{3}V} = \frac{100 \times 10^3}{\sqrt{3} \times 11 \times 10^3} = 5.25 \text{ Amp.}$$

→ Starting current (200%) :-

$$= \frac{5.25 \times 200}{100}$$

$$= 10.5 \text{ Amp.}$$

→ Size of conductor 6/2.11mm dia ACSR.

⇒ Secondary current :-

$$\Rightarrow I_2 = \frac{100 \times 10^3}{\sqrt{3} \times 0.4 \times 10^3} = 144.33 \text{ Amp}$$

→ Starting current (200%) :-

$$= \frac{144.33 \times 200}{100} = 288.66 \text{ Amp}$$

→ Size of conductor 37/2.18mm dia ACSR.

⇒ Length of cable :-

→ From tlb secondary to nearest pole = 1m.

→ From tlb height to cable box height = 1m

→ Wastage = 0.5m

⇒ Total length = 2.5m = 10m

2.5m

→ Height
→ From

Fuse


Operati
handle
to isolate

11/03/20
100KV
tion

→ Height of jumper wire; -

→ From tlb bussing to isolator = 1m

→ total = $1 \times 3 = 3m$



Amp

1m.

1m

⇒ Material list:-

1. H-type pole → 1 set
2. MS channel (mild steel) cross arm → 6 no. $\times \frac{12}{12}$
3. Lightning Arresters → 3 no. (11KV rating)
4. Isolator → 3 no. (11KV)
5. Disk type insulator → 6 no.
6. Pin insulator → 14 no. (3+3+4+4=14)
7. Air break SW → 1 set
8. H.G. (High grade) base → 3 no. (11KV)
9. Conductor (ACSR) → 6/2.11mm (Primary)
→ 37/2.18mm (Secondary)
10. Support →
11. Jumpers → 3m Chushing to pin insulator.
12. Transformers → 100KVA, (11/0.4KV)
13. Cut out → 3 no.
14. Z-clamp → 20 no.
15. OCB →
16. Stay set → 20 no.
17. Earthing → 2 no.
18. Dangers plate → 1 no.
19. R.S. joint (supporting) → 4 no.
20. Nut-bolt → As per required
21. Anti-climbing device → 1 no.

Ch-5 Service Connection 3

Dt-13/03/2020

Q) Prepare a list of material for giving service conn^c to a single storied building a 230V, 50Hz, 1 ϕ having a load of 5KW. The supply is to be given from overhead line 20m away from the building.

Solⁿ:-

→ Load calculation:-
 $P = VI$

$$\Rightarrow I = \frac{5 \times 10^3}{230} = 21.73 \text{ Amp.}$$

→ Starting current (150%):-

$$\Rightarrow \frac{21.73 \times 150}{100} = 32.595 \text{ Amp.}$$

→ The diameter of conductor (AAC - All aluminium conductor) of 36 amp is 1/3.55 mm and area 10mm². (According to conductor charge).

→ Length of GI pipe:-

→ Ground clearance of conductor + vertical deviation due to sag + top bending + wall crossing - meter clearance from ground

$$\Rightarrow 5.8 + 0.2 + 0.5 + 0.25 - 2.5 = 4.25 \text{ m}$$

→ Length of conductor:-

→ $2 \times (\text{span length} + 3\% \text{ of sag of the span length} + \text{GI pipe length} + 1 \text{ m. swing at the pole} + 0.5 \text{ m sagging at the pipe} + 10\% \text{ wastage at the span length})$

$$= 2 \times \left(20 + \frac{3 \times 20}{100} + 4.25 + 1 + 0.5 + \frac{10 \times 20}{100} \right)$$

$$= 2 \times (20 + 0.6 + 4.25 + 1 + 0.5 + 2)$$

$$= 56.7 \text{ m}$$


⇒ Length of GI support wire:-

⇒ (Span length + 3% sag + 1m. bending at the pole + 0.5m bending at the pipe)

$$\Rightarrow 20 + 0.6 + 1 + 0.5 = 22.1 \text{ m}$$

⇒ Assumptions:-

- Total height of ground block = 3.5m
- Height of service connection received = 5.8m
- Height of energy meters from the ground = 2.5m
- Height of energy meters from the ground = 2.5m



⇒ Material Terms

1) Length of

2) Length of

3) Length of all

4) Fuse

5) Neutral

6) Stay

7) Saddle

8) Mild steel

9) Meters

from c

10) Multie

11) Nut &

12) Prepare

a double

the sup

a load

on e

from

be'd

⇒ Material list :-

<u>Terms</u>	<u>Specification</u>	<u>Quantity</u>
1) Length of GI pipe	= 15mm ²	4.25m
2) Length of GI support wire	= 8SWG (standard wire)	22.1m gauge
3) Length of aluminium conductor	= 10mm ²	5-6.4m
4) Fuse	32A	1 no.
5) Neutral link	—	1 no.
6) Stay set	—	2m
7) Saddle	—	10 no.
8) Mild steel hook	—	4 no.
9) Meter board (500mm x 400mm)	—	1 no.
10) Nuttie	—	10 no.
11) Nut & bolt	—	15 no.

Q) Prepare a material list the service conn. to a double storeyed building having 2 energy meter the supply is to be given at 230V, 1φ having a load of 5 subckt. & 2 15Amp socket point on each floor ⁸⁰⁰. The supply ¹⁰⁰⁰ is to be given from over head line 20m. away from the building